



NOTIFIED BODY No. 1293

## EC – CERTIFICATE OF CONFORMITY

**No. 1293 – CPD – 0198**

on December 20, 2010

In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive – CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

### **Fire Alarm Control Panel OLYMPIA**

is a microprocessor-programmable control panel for fire detection with an analogue addressed system and an autonomous administration of the annunciator and warning procedures

**placed on the market by**

**TELEDATA s.r.l.**

**Via Giulietti 8, 20132 Milano, Italy**

**and produced in the factory**

**TELEDATA s.r.l.**

**Via Giulietti 8, 20132 Milano, Italy**

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the approved body EVPÚ a.s., Notified Body No. 1293 has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the Standard (resp. in)

**EN 54-2: 1997/A1: 2006/AC: 1999, EN 54-4: 1997/A2: 2006/AC: 1999**

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on December 20, 2010 and remains valid as long as the conditions laid down in the harmonized technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.



Karol Glamoš



Marking may only be used if conformity with all relevant and effective Directives of EP and Council is attested.