

**ANNEX I TO CERTIFICATE OF CONFORMITY OF CONSTANCY OF PERFORMANCE
1922-CPR-0499/ 16.10.2015**

Essential characteristic	Compliance	Clause
<i>Nominal activation conditions / Sensitivity and Performance under fire conditions</i>		
- Alarm condition	pass	4.3.2
- Indicators for alarm condition	pass	4.4
- Safety aspects	pass	4.7.1
- Protection against accidental operation	pass	4.7.4
- Operational performance test	pass	5.2
- Function test	pass	5.3
<i>Operational reliability</i>		
- Marking and data	pass	4.2
- Normal condition	pass	4.3.1
- Reset facility	pass	4.5
- Test facility	pass	4.6
- Shape, dimensions and colours	pass	4.7.2
- Symbols and lettering	pass	4.7.3
- Environment category	pass	4.7.5
- Additional requirements for software controlled manual call points	N/A	4.8
- Test facility test (operational)	pass	5.4
- Reliability test (endurance)	pass	5.5
<i>Durability of operational reliability, temperature resistance</i>		
- Dry heat (operational)	pass	5.7
- Dry heat (endurance)	pass	5.8
- Cold (operational)	pass	5.9
<i>Durability of operational reliability, vibration resistance</i>		
- Shock (operational)	pass	5.14
- Impact (operational)	pass	5.15
- Vibration, sinusoidal (operational)	pass	5.16
- Vibration, sinusoidal (endurance)	pass	5.17
<i>Durability of operational reliability, humidity resistance</i>		
- Damp heat, cyclic (operational)	pass	5.10
- Damp heat, cyclic (endurance)	pass	5.11
- Damp heat, steady state (endurance)	pass	5.12
- Enclosure protection	pass	5.19
<i>Durability of operational reliability, corrosion resistance</i>		
- Damp heat, cyclic (endurance)	pass	5.11
- Sulphur dioxide (SO ₂) corrosion (endurance)	pass	5.13
<i>Durability of operational reliability, electrical stability</i>		
- Variation of supply parameters	pass	5.6
- Electromagnetic compatibility (EMC), (operational)	pass	5.18



Embossed stamp of "Dedal - A&C" Ltd.



Manager:

arch. Galina Vasileva