

CERTIFICATE

of constancy of performance

1922 - CPR - 0696

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction products

**Fire detection and fire alarm systems. Control and indicating equipment.
Power supply equipment - MC 5, PC 5**

(with the performance listed, see Annex I to 1922-CPR-0000 that is an inseparable part of this certificate)

placed on the market under the name or trade mark of

Sana Pajouhesh Gostar Co. SENS

No. 3, 2nd West Alley, Irdak Industrial St., Tabriz, Iran

and produced in the manufacturing plant of

Sana Pajouhesh Gostar Co. SENS

No. 3, 2nd West Alley, Irdak Industrial St., Tabriz, Iran

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

**EN 54-2:1997, EN 54-2:1997/AC:1999, EN 54-2:1997/A1:2006 and EN 54-4:1997,
EN 54-4:1997/AC:1999, EN 54-4:1997/A1:2002, EN 54-4:1997/A2:2006**



under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 10.08.2016 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified factory production control certification body. The certificate is supported through annual surveillance audit and is reissued after each surveillance audit. This certificate should be reissued not later than 10.08.2017. The validity of this certificate can be verified in the CE register on www.dedal-bg.net.



Issued:
Burgas, 10 August 2016

Embossed stamp of "Dedal - A&C" Ltd.

Manager: 


arch. Galina Vasileva

ANNEX I TO CERTIFICATE OF CONSTANCY OF PERFORMANCE 1922 - CPR - 0696/10.08.2016 (page 1 of 2)

Performance list, acc. to EN 54-2:1997, EN 54-2:1997/AC:1999, EN 54-2:1997/A1:2006

<i>Performance under fire conditions</i>	<i>Performance</i>	<i>Clause</i>
- General requirements	pass	4
- General requirements for indications	pass	5
- The fire alarm condition	pass	7
Response delay (response time to fire)		
- Reception and processing of fire signals	pass	7.1
- Output of the fire alarm condition	pass	7.7
- Delay to outputs	pass	7.11
- Dependencies on more than one alarm signal	pass	7.12
Operational reliability		
- General requirements	pass	4
- General requirements for indications	pass	5
- The quiescent condition	pass	6
- The fire alarm condition	pass	7
- Fault warning condition	pass	8
- Disabled condition	pass	9
- Test condition	pass	10
- Standardized input/output interface	pass	11
- Design requirements	pass	12
- Additional design requirements for software controlled control and indicating equipment	pass	13
- Marking	pass	14
Durability of operational reliability, temperature resistance		
- Cold (operational)	pass	15.4
Durability of operational reliability, vibration resistance		
- Impact (operational)	pass	15.6
- Vibration, sinusoidal (operational)	pass	15.7
- Vibration, sinusoidal (endurance)	pass	15.15
Durability of operational reliability, electrical stability		
- Electromagnetic compatibility (EMC), immunity tests (operational)	NPD	15.8
- Supply voltage variations	pass	15.13
Durability of operational reliability, humidity resistance		
- Damp heat, steady state (operational)	pass	15.5
- Damp heat, steady state (endurance)	pass	15.14



Issued:
Burgas, 10 August 2016

Embossed stamp of "Dedal - A&C" Ltd.



Manager:

arch. Galina Vasileva

ANNEX I TO CERTIFICATE OF CONSTANCY OF PERFORMANCE 1922 - CPR - 0696/10.08.2016 (page 2 of 2)

Performance list, acc. to EN 54-4:1997, EN 54-4:1997/AC:1999, EN 54-4:1997/A1:2002, EN 54-4:1997/A2:2006

<i>Performance of power supply</i>	<i>Performance</i>	<i>Clause</i>
- General requirements	pass	4
- Functions	pass	5
- Materials, design and manufacture	pass	6
Operational reliability		
- General requirements	pass	4
- Functions	pass	5
- Materials, design and manufacture	pass	6
- Documentation	pass	7
- Marking	pass	8
Durability of operational reliability, temperature resistance		
- Cold (operational)	pass	9.5
Durability of operational reliability, vibration resistance		
- Impact (operational)	pass	9.7
- Vibration, sinusoidal (operational)	pass	9.8
- Vibration, sinusoidal (endurance)	pass	9.15
Durability of operational reliability, electrical stability		
- Electromagnetic compatibility (EMC), immunity tests (operational)	NPD	9.9
Durability of operational reliability, humidity resistance		
- Damp heat, steady state (operational)	pass	9.6
- Damp heat, steady state (endurance)	pass	9.14

This certificate was first issued on 10.08.2016 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified factory production control certification body. The certificate is supported through annual surveillance audit and is reissued after each surveillance audit. This certificate should be reissued not later than 10.08.2017. The validity of this certificate can be verified in the CE register on www.dedal-bg.net.



Embossed stamp of "Dedal - A&C" Ltd.

Manager:




arch. Galina Vasileva